



**Williamsburg - James City County Public School Division
Invitation for Bid 14-6422
Chemical Treatment of Water**

DATE: April 22, 2014

ADDENDUM NO. 1

This Addendum is provided to answer bidder's questions. Please contact Jenise Howard, Jenise.Howard@jamecitycountyva.gov, if you have questions pertaining to this addendum.

The above referenced IFB is hereby amended and clarified as follows:

The following modifications, additions, and deletions are *hereby incorporated into the contract documents*.

QUESTIONS:

1. What is the TONNAGE of the cooling towers?

Answer: The one BAC closed circuit cooler system at Norge ES is rated at 2,100,000 BTU's. The Marley evaporative cooler at Norge ES is hooked to a 180 ton chiller. Unfortunately the rest of our towers are Evapco closed circuit coolers and Evapco does not rate them in BTU's. The model numbers are listed below for individual specification research.

Toano MS – ESWA-153-46J

Clara Byrd Baker ES – ESWA-102-33J

D.J. Montague ES – ATWB-3-3JB

J.B. Blayton ES – ATW-77-31-Z

Hornsby MS – ATW-102-3J-Z

Berkeley MS – LSWA-153-46J

James Blair Central Office – LSWA-87-B

2. What is the online time for the Cooling Tower Systems? Summer, winter seasons?

Answer: Our seasons vary a little bit due to the weather. But we typically winterize the water treatment systems around Thanksgiving and restart them in late March. This will vary a week or two on each and depending on the current weather conditions. Once they are started in the spring they run all summer long.



**Williamsburg - James City County Public School Division
Invitation for Bid 14-6422
Chemical Treatment of Water**

This Addendum 1 is incorporated into the Bid Documents and will be made part of the resulting contract. Please acknowledge receipt of this Addendum in the space provided in the proposal form section of the Invitation for Bid.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.